

Certificate

Registration No.: PV 50163799

Page 2

Report No.: 12605438 009

License Holder:

CSG PVTech Co., Ltd.

CSG Green Energy Industrial Park,
Machong, Dongguan,
Guangdong, 523141, P. R. China

Product:

PV Module

Addition

Type: CSGaaaM2-35/1956x992
CSGbbbM2-30/1640x992
CSGxxxM2-26/1482x992
CSGyyyM2-24/1324x992
CSGzzzM2-17/1482x674

Manufacturing Plant:

CSG PVTech Co., Ltd.

CSG Green Energy Industrial Park,
Machong, Dongguan,
Guangdong, 523141, P. R. China

aaa = 285, 290, 295 or 300

bbb = 235, 240 or 245

xxx = 215 or 220

yyy = 190 or 195

zzz = 145

Basis:

- IEC 61215:2005**
EN 61215:2005
"Crystalline silicon terrestrial
photovoltaic (PV) modules - Design
qualification and type approval"

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.



- **Periodic inspection**
- **Qualified, IEC 61215**
- **Safety tested, IEC 61730**

Remarks:

- Additional type designations see above.
- The details of the factory inspection are documented in report no. 12606132.
- Mechanical load at 5400 Pa has been performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid for 5 years from the date of issue stated on page 1.



Certification body



Dipl.-Ing. S. Hartter

Yokohama, 22 July 2010